

# PRODUCT-TYPE TEST



The applicant:

**NOBILIS**  
29 RUE BONAPARTE  
FR-75006 PARIS

In compliance with the Regulation (UE) No. 305/2011 laying down harmonized conditions for the marketing of construction products, has performed reaction to fire type testing in:



**aitex**  
textile research institute

**Notified Testing Laboratory No. 0161**

**Document No. 16AN2494**

Attending the set conditions for the CE marking detailed at Annex ZA of the harmonised product standard **EN 15102:2007+A1:2011**, the notified laboratory declares on its classification report No. 2016AN2494 that the **decorative wall covering** referenced as:

**“MQT20 à MQT35”**

has been tested according to the requirements described at product standard, achieving the EN 13501-1:2007+A1:2009 classification

**“B-s1,d0”**

Product, tests and field of application details are stated on the annex A of this document.

Alcoy, December 3rd 2015.



*P.A. [Signature]*

**Raquel Muñoz González**  
CHIEF OF INNOVATION AREA

## TYPE TESTING – Annex A

### A.1 PRODUCT-TYPE DETAILS

#### A.1.1 General:

Coated wallpaper in roll form, to be installed using an adhesive on internal wall, partitions or ceilings, and having the main purpose of decoration.

#### A.1.2 Product description provided by the applicant:

<b>Composition</b>	Out side: 26.1% Paulownia / Inner side: 22.8 resin / Back side: 51.1% non woven fabric, according to client.
<b>Weight</b>	234 g/m <sup>2</sup> , according to client.
<b>Thickness</b>	0.46 mm, according to client.

### A.2 CLASSIFICATION REPORT

Laboratory identification	Product reference	Report reference	Achieved classification
AITEX	MQT20 à MQT35	2016AN2494	B-s1,d0

### A.3 FIELD OF APPLICATION OF THE CLASSIFICATION

This classification might be affected if any of the following influence parameters is modified:

<b>A.2.1. Product parameters:</b>	
Thickness	0.46 mm, according to client.
Weight	234 g/m <sup>2</sup> , according to client.
<b>A.2.2. End use applications:</b>	
Substrates	Non combustible (Euroclass A2-s1d0 or better) with density higher than 1600 kg/m <sup>3</sup> , thickness greater than 6 mm.
Mounting	Vertical edge to edge joints.
Fixing	Glued directly to substrate using vinyl adhesive.

### A.4 LIMITATIONS

The classification assigned to the product in this report is appropriate to a declaration of the performance by the manufacturer within the context of a system 3 assessment of constancy of performance and CE marking under the Construction Products Regulation according to clauses ZA.2.2 and ZA.3 of the harmonized product standard EN 15102:2007+A1:2011.

The manufacturer has made a declaration, which is held on file. This confirms that the product's design requires no specific processes, procedures or stages (e.g. no addition of flame retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability.