



aitex®
research & innovation center

REACTION TO FIRE

Applicant:

NOBILIS

29 RUE BONAPARTE
FR-75006 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN2740.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN2740

"CORK III"

The sample referenced as:

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"C-s1,d0"

Date of Issue

3rd of November 2025

Date: 04/11/2025 9:49:52
Digitally Signed by:JOAN RISUEÑO CABANES -
NIF:48605765A

Joan Risueño
Head of Fire Behaviour lab.