



aitex®
research & innovation center

REACTION TO FIRE

Applicant:

NOBILIS

29 RUE BONAPARTE
FR-75006 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN2463.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN2463



The sample referenced as:

"PRINTED ON BALI BASE "



has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

16th of October 2025

Date: 16/10/2025 17:34:07

Digitally Signed by:JOAN RISUEÑO CABANES -
NIF:48605765A

Joan Risueño
Head of Fire Behaviour lab.