

REACTION TO FIRE

Applicant:

NOBILIS

29 RUE BONAPARTE
FR-75006 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2026AN1550.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 26AN1550

The sample referenced as:

"LASER ENGRAVING ON WOOD"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

19th of June 2026

Date: 19/06/2026 13:19:50

Digitally Signed by: JOAN RISUEÑO CABANES -
NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.