

REACTION TO FIRE

Applicant:

NOBILIS

29 RUE BONAPARTE
FR-75006 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2026AN2234.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 26AN2234

The sample referenced as:

"STL1 ORNATE"

has been tested according to the standards EN ISO 11925-2:2026 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

18th of September 2026

Date: 18/09/2026 13:48:35

Digitally Signed by: JOAN RISUEÑO CABANES -
NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.