

## REACTION TO FIRE

### Applicant:

NOBILIS

29 RUE BONAPARTE  
FR-75006 PARIS

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2026AN2238.



### CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 26AN2238

The sample referenced as:

**"STL6 LINE"**

has been tested according to the standards EN ISO 11925-2:2026 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

**"B-s1,d0"**

Date of Issue

22nd of September 2026

Date: 23/09/2026 12:34:36

Digitally Signed by: JOAN RISUEÑO CABANES -  
NIF: 48605765A

Joan Risueño  
Head of Fire Behaviour lab.